
## Document No:ZQK-332(165)



- -Fixation and support of the piping-
- Please install the expansion joint so that the piping weight does not influence to the product.
- ② Please prepare the guide so that the piping does not swing sideways.③ Please install the expansion joint so that the distance from the anchor
- to the product may be within 4 times of the pipe diameter.  $\bigcirc$
- (4) Please design the anchor to endure thrust due to internal pressure and the reaction force of the bellows.
- Please carry out the welding work of the piping before the attachment of our product. If you have to carry out the welding work after attaching the piping, please earth the welding properly, also put a protective cover around our product so that the welding current does not flow into the piping system.
- 2) Please do not elongate and compress the product at the time of the installation.