Document No:ZQK-332(128)

the setting bolts

After tightening bolts for flange.

ℜ The expansion joint does not

when set bolt is still kept

work sufficient function


in the product.


please dismount the set bolt.

Installation Manual for the Stainless Expansion Joint

ZENSHN

4. Detaching of





NOTES

1

- 1) Please do not hit a product at the time of the transportation and the installation.
- 2) Please carry out the welding work of the piping before the attachment of our product. If you have to carry out the welding work after attaching the piping, please earth the welding properly, also put a protective cover around our product so that the welding current does not flow into the piping system.
- 3) Please do not elongate and compress the product at the time of the installation.