


1. Applications and Features

Purpose	Gap adjustment of plumbing, Absorbing lateral movement
Location	No vibration pipe line
Features	Threaded flexible joint with fixed nipple on one side and union joint on the other.

2. Structure and Parts

Figure 1 shows the structure, and Table 1 shows the part names and materials.



Z-12000

Figure 1 . Structure

Table1. Parts List

No.	Name	Material
1	Bellows	Stainless steel 304
2	Braide	Stainless steel 304
3	Union screw	Stainless cast steel
4	Union nut	Stainless cast steel
5	Union guard	Stainless cast steel
6	Union collar	Stainless steel 304
7	Gasket	Joint sheet without asbestos
8	Braide cover	Stainless steel 304
9	Nipple	Stainless steel 304

3. Dimensions and maximum working pressure

Table 2 shows dimensions and maximum working pressure.

Table2. Dimensions and maximum working pressure Unit : mm

Size	Bellows			Max. working pressure (MPa)
	ϕ A	ϕ B	t	
10A	10.5	15.0	0.25	1.0
15A	13.0	18.4	0.25	1.0
20A	19.1	25.4	0.3	1.0
25A	25.5	32.2	0.3	1.0
32A	33.5	40.3	0.3	1.0
40A	39.5	47.6	0.35	1.0
50A	53.0	61.6	0.35	1.0
65A	66.0	77.0	0.4	1.0

※Maximum working pressure is at normal temperature.

4. Minimum bend radius and total length required for each displacement

Table 3 shows the minimum bend radius and the total length required for each displacement.

Table 3. minimum bend radius and total length required for each displacement

Unit : mm

Size	Min. bend radius	Displacement					
		50	100	150	200	250	300
10A	35	350	400	500	550	600	650
15A	50	350	400	500	550	600	650
20A	65	400	500	600	650	750	800
25A	80	450	550	650	750	800	850
32A	100	500	650	750	850	950	1000
40A	120	500	650	800	900	1000	1050
50A	140	550	750	850	1000	1100	1150
65A	220	650	800	950	1100	1200	1300

<Design condition> Pressure : Maximum working pressure (B1)

Temperature : Normal temperature

Number of times repeated : More than 3,000 times

5. Applicable temperature range

Standard gasket : -20℃~100℃

Steam gasket : 100℃~180℃

6. InspectionInspection items : Visual inspection, Dimensional inspection (Overall length),
Leak inspection

Frequency : ALL

7. Notes

- Please inquire separately when used for piping with severe vibration and pressure fluctuation.
- The non-asbestos gasket included in the standard specifications cannot be used for steam piping.
If you wish to use it for steam piping, please specify “with steam gasket” when ordering.
- Please refer to the “Installation Instructions” for installation procedures.